



ADDENDUM-II
Tender No. 320000596 for Supply of Grid Power transformer 110/34.5kV with NIFPS at Mangalore Refinery & Petrochemicals Ltd, Aromatic Complex, SEZ Unit



Addendum-II to tender document is as follows:

Sl.	Details	MRPL Replies/Clarifications/Amendment/Corrigendum
1	We will consider tolerance for impedance as per IEC. Please note that IEC never specify about the base MVA of transformer on which the value to be consider. It will be provided by the user and hence we request you to provide the same.	10% impedance shall be considered on ONAF rating, that is 45 MVA. Tolerance values shall be considered as per IEC.
2	Due date of bid submission	Last date & time to submit the bid is extended to 15:00 HOURS (IST) ON 25-Nov-2022.

All other terms & conditions, stipulations, specifications etc. of tender document issued earlier shall remain unaltered. This forms an integral part of bidding document. Bidders are requested to take cognizance of the same and submit their bids accordingly. Bidders are requested to submit the copy of this document duly signed & stamped along with the bid (in the techno-commercial part) as the token of acknowledgement & acceptance of the same.

Sign & Stamp of Bidder