

MANGALORE REFINERY & PETROCHEMICALS LTD.
(A subsidiary of Oil & Natural Gas Corpn. Ltd – ONGC)
Regd. Office: Kuthethoor P.O., Via: Katipalla, Mangalore-575030 (India)
Phone: 0091-824-2270400 Fax: 0091-824-2271239

Addendum-1 dated 17.05.2023

To

Tender No. 3300010195 dated 02.05.2023

For

Main EPC Package For MRPL Aromatic Complex
Power System Upgradation Project

With reference to the above tender, bidders are requested to note the following:

The items, conditions, specification and stipulations of the Bidding Documents and the modified portion to the extent indicated in

- a) Annexure-I: Commercial Addendum
- b) Annexure-II: Technical Addendum
- c) Annexure-III: Reply to Pre-bid Queries

The implications of the same, elsewhere in the tender shall be taken care of appropriately by the bidders. All other terms and conditions, stipulations and specifications of tender shall remain unaltered.

Note:

Bidder shall submit copy of these documents along with the techno-commercial bid, **duly signed and stamped**, as a token of having read and understood the same.

Addendum-1**Annexure-I: Commercial Addendum**

<u>Sl. No.</u>	<u>Reference Section No./ Clause No.</u>	<u>Addition/Deletion/Modification</u>
1.	<u>Vol. I of II; Page 1 of 484;</u> <u>Tender Download End</u> <u>Date & Time</u>	<u>The Tender Download End Date & Time shall be read as</u> <u>07.06.2023, 15.00 Hrs</u>
2.	<u>Vol. I of II; Page 1 of 484;</u> <u>Bid Closing Date & Time</u>	<u>The Bid Closing Date & Time shall be read as</u> <u>07.06.2023, 15.00 Hrs</u>
3.	<u>Vol. I of II; Page 1 of 484;</u> <u>Un-Priced Bid Opening</u> <u>Date & Time</u>	<u>The Un-Priced Bid Opening Date & Time shall be read</u> <u>as 07.06.2023, 15.30 Hrs</u>
4.	<u>Vol. I of II; Page 5 of 484;</u> <u>Duration of Contract/</u> <u>Contract Period</u>	<u>Duration of Contract Period shall be Nine (9) months</u> <u>from the date of issue of Letter of Acceptance</u>
5.	<u>Vol. I of II; Page 378 of</u> <u>484; SCC Part-2;</u> <u>Annexure-I to SCC for</u> <u>Time Schedule</u>	<u>Time for completion of work shall be read as Nine (9)</u> <u>months</u>
6.	<u>Vol. I of II; Schedule of</u> <u>Quantity: Part-1</u> <u>(Electrical Items); Sheet</u> <u>no. 3 of 9, Serial no.</u> <u>13.03a</u>	<u>The quantity for 1C x 630 sq. mm, 33 kV Al. XLPE,</u> <u>armoured Cable between SS-10 and SS-01A shall be</u> <u>read as 0 m for Supply (Part-A) and 27000 m for</u> <u>Erection, Testing & Commissioning (Part-B)</u>

Addendum-1

Annexure-II: Technical Addendum

<u>Sl. No.</u>	<u>Reference Section No./ Clause No.</u>	<u>Addition/Deletion/Modification</u>
1.	<u>Vol. II of II, Part-A; Clause No. 12: Vendor List</u>	<u>Serial no. 1, Electrical, 110 kV Switchyard Equipment, Approved manufacturers shall be read as: For all 110 kV equipment: Siemens, ABB, BHEL, CGL, GE, Hitachi, The following makes are also approved for the equipment specified in the bracket: GR Power (Isolator), S&S (Isolator), Oblum (LA), Elpro (LA), WS Insulator (LA), Pragati Electricals (CT & PT), Toshiba (CT & PT), Mehru (CT & PT)</u>

Addendum-1

Annexure-III: Reply to Pre-bid Queries raised in the Pre-bid Meeting held on 12.05.2023

<u>Sl. No.</u>	<u>Reference Section No./ Clause No.</u>	<u>Subject</u>	<u>Bidder's Query</u>	<u>Owner's Reply</u>
1.	Vol. II of II; Vendor List	Vendor List	Some more manufacturers should be included for 110 kV equipment	Noted. Please refer to Annexure-II above.
2.	Vol. I of II; Bid Closing Time	Bid Closing Time	One week extension is requested.	Noted. Please refer to Annexure-I above.
3.	Vol. I of II; Page 378 of 484; SCC Part-2; Annexure-I to SCC for Time Schedule	Time for Completion of Work	Two months extension is requested.	Noted. Please refer to Annexure-I above.
4.	Vol. I of II; Page 8 of 484: BQC	BQC Criteria	Whether experience with 132 kV can be considered.	It is clarified that the tender document says bidder must have executed 110 kV or above Substation/Switchyard. So, naturally, experience with 132 kV is acceptable.
5.		Site Visit	Bidders requested for site visit for better assessment of the work/land profile.	The owner confirmed that the bidders can do site visits as required. The contact person from MRPL shall be Mr. Deepak G Kudva (96117 11737).