



# MANGALORE REFINERY & PETROCHEMICALS LTD.

(A Subsidiary of Oil and Natural Gas Corporation Ltd.)

---

## Addendum 01

To

**MRPL Tender No. 3200000931 dated 08.11.2024**

**Project Management Consultancy (PMC) Services for Construction of New Main Canteen Building at MRPL, Mangaluru, Karnataka.**

**With reference to the above tender, bidders are requested to note the following:**

The items, conditions, specification and stipulations of the Bidding Documents and modified to the extent indicated in

**a. Annexure-I – Replies to Tender Queries**

The implications of the same, elsewhere in the tender shall be taken care of appropriately by the bidders. All other terms and conditions, stipulations and specifications of tender shall remain unaltered.

**Note:**

Bidders shall submit copy of these documents along with the technical–commercial bid, **duly signed and stamped**, as a token of having read and understood the same.

**Annexure 1 – Replies to Tender Queries**

<b>Sl.No</b>	<b>Tender Queries</b>	<b>Clause SOW</b>	<b>Technical / Commercial</b>	<b>Answer from Client</b>
1	Please specify the voltage level and approximate distance from the point of supply of Electric power to the proposed Canteen Building.	General	Technical	Voltage level 415 volts. Distance from source approx. 200 m.
2	Please Clarify Electrical Installation are inspected by State Inspectorate Team or by Central Inspectorate Team	General	Technical	Central Electricity Authority(CEA)
3	Please clarify whether to consider the back-up Diesel Genset for the canteen building.	General	Technical	Not Envisaged
4	Please specify the areas / sections within the canteen building which requires air conditioning / walk-in cooler / deep freezer.	General	Technical	Will be intimated to success full bidder
5	SD or portion of SD will be refunded within 15 days after the satisfactory completion of the contract or after the expiry of the Defects Laibility Period wherever applicable. DLP is 12 Months as per EXHIBIT - 7, Warrantees and Gaurantees Clause No.2.3	Article 21: Clause 21.3 102 &166	Clarification on DLP	Tender terms shall prevail
6	Plot area of existing canteen building will be dismantled for construction of new canteen building on same area.	General	Technical	Attached

Total Area for  
Canteen: 1500SQM

